

# UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
 Myrtle Creek, Oregon 97457  
 (541) 863-5201 Fax: (541) 863-6199  
 E-mail: Lab@URCmail.net  
 Internet: http://ChemLab.cc  
 ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 6102101

Oakland School District #1	Project: General Testing	Date Reported: 10/28/16
P O Box 390		Date Received: 10/21/16 09:50
Oakland, OR 97462		Sampled By: Leon Rosson
Client Contact: Attn: Leon Rosson		

### Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
6102101-01	Sample Location: Room #1 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/20/16 04:55	10/26/16	DJP	
<b>Copper</b>			0.122	mg/L	0.010	1.3	10/20/16 04:55	10/26/16	DJP	
6102101-02	Sample Location: Room #2 Drinking Fountain									
<b>Lead</b>		1030	0.004	mg/L	0.002	0.02	10/20/16 05:05	10/26/16	DJP	
<b>Copper</b>			0.119	mg/L	0.010	1.3	10/20/16 05:05	10/26/16	DJP	
6102101-03	Sample Location: Room #6 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/20/16 04:46	10/26/16	DJP	
<b>Copper</b>			0.051	mg/L	0.010	1.3	10/20/16 04:46	10/26/16	DJP	
6102101-04	Sample Location: Room #7 Drinking Fountain									
<b>Lead</b>		1030	0.007	mg/L	0.002	0.02	10/20/16 04:37	10/26/16	DJP	
<b>Copper</b>			0.057	mg/L	0.010	1.3	10/20/16 04:37	10/26/16	DJP	
6102101-05	Sample Location: Room #8 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/20/16 04:30	10/26/16	DJP	
<b>Copper</b>			0.074	mg/L	0.010	1.3	10/20/16 04:30	10/26/16	DJP	
6102101-06	Sample Location: Room #9 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/20/16 04:27	10/26/16	DJP	
<b>Copper</b>			0.057	mg/L	0.010	1.3	10/20/16 04:27	10/26/16	DJP	
6102101-07	Sample Location: Room #10 Drinking Fountain									
Lead		1030	0.002	mg/L	0.002	0.02	10/20/16 04:24	10/26/16	DJP	
<b>Copper</b>			0.092	mg/L	0.010	1.3	10/20/16 04:24	10/26/16	DJP	
6102101-08	Sample Location: Room #11 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/20/16 04:06	10/26/16	DJP	
<b>Copper</b>			0.109	mg/L	0.010	1.3	10/20/16 04:06	10/26/16	DJP	
6102101-09	Sample Location: Room #12 Drinking Fountain									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



# UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
 Myrtle Creek, Oregon 97457  
 (541) 863-5201 Fax: (541) 863-6199  
 E-mail: Lab@URCmail.net  
 Internet: http://ChemLab.cc  
 ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 6102101

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	ND	mg/L	0.002	0.02	10/20/16 04:03	10/26/16	DJP	
<b>Copper</b>			0.078	mg/L	0.010	1.3	10/20/16 04:03	10/26/16	DJP	
6102101-10	Sample Location: Room #13 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.02	10/20/16 04:00	10/26/16	DJP	
<b>Copper</b>			0.025	mg/L	0.010	1.3	10/20/16 04:00	10/26/16	DJP	
6102101-11	Sample Location: Kitchen Prep Sink									
Lead		1030	ND	mg/L	0.002	0.02	10/20/16 05:15	10/26/16	DJP	
<b>Copper</b>			0.066	mg/L	0.010	1.3	10/20/16 05:15	10/26/16	DJP	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



## UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
Myrtle Creek, Oregon 97457  
(541) 863-5201 Fax: (541) 863-6199  
E-mail: Lab@URCmail.net  
Internet: <http://ChemLab.cc>  
ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 6102101

### Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

---

Tom Williams, Laboratory Manager