



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6071504

Oakland School District #1	Project: General Testing	Date Reported: 07/25/16
P O Box 390	Project #: Lead/Copper	Date Received: 07/14/16 15:46
Oakland, OR 97462	Client Contact: Attn: Leon Rosson	Sampled By: Leon Rosson

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
6071504-01	Sample Location: OES1 Drinking Fountain									
Lead		1030	0.006	mg/L	0.002	0.2	07/14/16 14:13	07/21/16	DJP	
Copper			0.079	mg/L	0.010	1.3	07/14/16 14:13	07/21/16	DJP	
6071504-02	Sample Location: OES2 Drinking Fountain									
Lead		1030	0.006	mg/L	0.002	0.2	07/14/16 14:15	07/21/16	DJP	
Copper			0.064	mg/L	0.010	1.3	07/14/16 14:15	07/21/16	DJP	
6071504-03	Sample Location: Lincoln1 Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.2	07/14/16 13:36	07/21/16	DJP	
Copper			0.295	mg/L	0.010	1.3	07/14/16 13:36	07/21/16	DJP	
6071504-04	Sample Location: Lincoln2 Annex Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.2	07/14/16 13:40	07/21/16	DJP	
Copper			0.274	mg/L	0.010	1.3	07/14/16 13:40	07/21/16	DJP	
6071504-05	Sample Location: OHS1 Long Hall Drinking Fountain									
Lead		1030	ND	mg/L	0.002	0.2	07/14/16 14:26	07/21/16	DJP	
Copper			0.056	mg/L	0.010	1.3	07/14/16 14:26	07/21/16	DJP	
6071504-06	Sample Location: OHS2 Short Hall Drinking Fountain									
Lead		1030	0.013	mg/L	0.002	0.2	07/14/16 14:23	07/21/16	DJP	
Copper			0.016	mg/L	0.010	1.3	07/14/16 14:23	07/21/16	DJP	
6071504-07	Sample Location: OHS Boys Locker Rm Drinking Fountain									
Lead		1030	0.004	mg/L	0.002	0.2	07/14/16 14:33	07/21/16	DJP	
Copper			0.055	mg/L	0.010	1.3	07/14/16 14:33	07/21/16	DJP	
6071504-08	Sample Location: OHS Girls Locker Rm Drinking Fountain									
Lead		1030	0.016	mg/L	0.002	0.2	07/14/16 14:36	07/21/16	DJP	
Copper			0.011	mg/L	0.010	1.3	07/14/16 14:36	07/21/16	DJP	
6071504-09	Sample Location: Cafeteria Drinking Fountain									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6071504

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	0.002	mg/L	0.002	0.2	07/14/16 14:20	07/21/16	DJP	
Copper			0.014	mg/L	0.010	1.3	07/14/16 14:20	07/21/16	DJP	

UMPQUA Research Company/MC

Tom Williams, Laboratory Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6071504

Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

Tom Williams, Laboratory Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.